

## 2022 Water Quality Data

Monitoring Performed by Village of Catlin - PWSID # IL1830150

Contaminant (units)	Collection Date	MCLG	MCL	Level Found	Range of Detections	Violation	Typical Source of Contaminant
Disinfectants/Disinfection By-Product							
Total Trihalomethanes (ppb)	2022	NA	80	18	18-18	No	By-product of drinking water disinfection.
Chlorine (ppm)	2022	MRLDG=4	MRDL 4	1.7	1-2	No	Water additive used to control microbes.
Haloacetic acids (ppb)	2022	NA	60	14	14.3-14.3	No	By-product of drinking water disinfection.

Not all sample results may have been used for calculating the Highest Level Detected because some of the results may be part of an evaluation to determine where compliance sampling should occur in the future.

Copper Results							
Contaminant & unit of measurement	Date Sampled	MCLG	Action Level (AL)	90 <sup>th</sup> Percentile	# Sites Over AL	Violation	Source
Copper (ppm)	2022	1.3	1.3	0.151	0	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Monitoring Performed by Aqua Illinois Vermillion County Division - PWSID # IL1835120

Contaminant (units)	Sample Date	MCLG	MCL	Level Found	Range of Detections	Violation	Major Sources in Drinking Water
Inorganic Contaminants							
Barium (ppm)	2022	2	2	0.0045	0.0045-0.0045	No	Erosion of natural deposits.
Fluoride (ppm)	2022	4	4	0.7	0.713-0.713	No	Erosion of natural deposits.
Nitrate (ppm)	2022	10	10	9 (a)	ND-9	No	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion of natural deposits.
Selenium (ppb)	2022	50	50	1	1.3-1.3	No	Erosion of natural deposits; discharge from mines.

(a) Nitrate: in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

Unregulated Contaminants							
Sodium (ppm)	2022	NA (b)	NA (b)	10	9.9-9.9	No	Erosion of naturally occurring deposits: road salt

(b) Sodium: There is no state or federal MCL for sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. People on a sodium-restricted diet should consult their physician about the level of sodium in the water they drink.

Synthetic Organic Contaminants							
Atrazine (ppb)	2022	3	3	1.3	ND-1.3	No	Herbicide runoff

Turbidity-Regulated at the water treatment plant: 95% of samples must be below 0.3 NTU.				
Limit (Treatment Technique)	Lowest monthly % meeting limit	Highest single measurement (1 NTU limit)	Violation	Source
0.3 NTU	100%	0.24	No	Soil Runoff

Lead and Copper Results								
Contaminant & unit of measurement	90 <sup>th</sup> Percentile	Total number of samples	Samples Exceed AL	Federal/State Standard Action Level	Ideal Goal MCLG	Last Monitoring Period	Violation	Source
Copper (ppm)	0.04	30	0	1.3	1.3	2020	No	Corrosion of household plumbing
Lead (ppb)	6.5	30	0	15	0	2020	No	

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials found in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing the line for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about the levels of lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

To view a summary version of the completed Source Water Assessments, including: Importance of Clean Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at:

<http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

# Village of Catlin 2022 Water Quality Report

Prepared by:  
**FEHR GRAHAM**  
ENGINEERING & ENVIRONMENTAL

1610 Broadmoor Drive  
Champaign, Illinois 61821

*With water quality data provided by the source water company:*

Aqua Illinois, Inc.  
1300 Fairchild Street  
Danville, Illinois 61834

## **The Water You Drink**

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 217-427-5221. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Illinois EPA considers all surface water sources of public water supply to be susceptible to potential pollution problems. Hence the reason for mandatory treatment of all public water supplies in Illinois. Mandatory treatment includes coagulation, sedimentation, filtration and disinfection. Primary sources of pollution in Illinois lakes can include agricultural runoff, land disposal (septic systems) and shoreline erosion.

Aqua Illinois, as the parent company providing water to the Village, is responsible for most of the required contaminant testing performed. You will be happy to know that there were no water quality violations in 2022 and that water supplied by Aqua Illinois is safe, clean and reliable. Aqua Illinois is committed to the continued monitoring of your system and to keeping you apprised of any changes to the system that could alter the quality of the water you drink. This means that you can rest assured that when you turn on your tap that quality water is what you'll get out of it.

## **Sources of Your Water**

The source of water for the Village of Catlin is from Aqua Illinois. Aqua Vermilion County Division uses surface water from the north fork of the Vermilion River as its water source. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

## **Treatment and Distribution**

The surface water is treated via the new treatment facility on West Fairchild Street which has had \$15 million dollars worth of improvements since 1992. In fact, since 1986, Aqua Illinois has invested over \$30 million in the water system. Besides raising Lake Vermilion, other improvements have included a new treatment facility and upgrade of the distribution system. These improvements through the 3 years help ensure the product meets all state and federal water quality standards.

The distribution system includes both the transmission main and the local water mains carrying water throughout the Village.

## **General Drinking Water Information**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity.

## **Contaminants that may be present in source water include:**

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides which may come from a variety of source such as agriculture, urban stormwater runoff and residual uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the United States Environmental Protection Agency (USEPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## **Unregulated contaminant monitoring (UCMR4)**

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every 5 years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWS). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR4 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of our UCMR4 monitoring in 2019. All other contaminants tested during UCMR4 were Not Detected.

<b>Unregulated Contaminants Detected During 2019</b>			
<b>Unregulated Contaminant</b>	<b>Average Detection</b>	<b>Range of Detections</b>	<b>MCL</b>
<b>Distribution Samples</b>			
HAA5, ppb	13.6	10.67-16.48	NA
HAA6Br, ppb	3.4	0.85-5.26	NA
HAA9, ppb	16.29	13.22-19.41	NA

*Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).*

## **Questions?**

Should you have any questions about this report or concerning your water system, please contact Tim McFadden at (217) 427-5221. We want you to be informed about your water quality. If you would like to learn more, please attend any of the regularly schedule Village Board meetings on the first and third Tuesdays of each month.

## **Important Health Information**

*Some people may be more vulnerable to contaminants in drinking water than the general population. immunocompromised persons, such as persons with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline, 1-800-426-4791 or your local public health district.*

## **Notes:**

### **Action Level (AL):**

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. Some levels are based on a running annual average.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**NA:** Not applicable. **ND:** Not detected.

**Nitrate:** Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice for your health care provider.

**NTU:** Nephelometric turbidity unit (cloudiness of water).

**ppb:** A unit of concentration equal to one part per billion or one ounce in 7,350,000 gallons of water.

**ppm:** A unit of concentration equal to one part per million or one ounce in 7,350 gallons of water.

**ppt:** A unit of concentration equal to one part per trillion.

**pCi/L, picocuries/Liter:** A unit of concentration for radioactive contaminants.

**Treatment Technique:** A required process intended to reduce the level of a contaminant in drinking water.

**Turbidity:** Monitored as a measure of treatment efficiency for removal of particles.

**Avg:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.